

Portable Appliance Test

Record Log

Name: Gary Evans (Gary Evans Photography)
Address: 280 Wootton Road
 Kings Lynn
 Norfolk
 PE30 3BJ

Telephone: 01553 672855
Mobile: 07957 493992
Email: gary@myeventphoto.co.uk

Test Date: 24 11 2017
Tested by: Martyn Mackie
Signature: *MRMackie*

Appliance ID	Item	Serial Number	Visual Inspection	Class 1 or 2	Fuse (Amps)	Operating Voltage	Power Rating	Earth Bond	Insulation Test	Pass or Fail	Notes
Light 1	Bowens Esprit GM500 Flash Head	ULO752	PASS	Class 1	5 Amp	240V		PASS	PASS	PASS	
Lead 1	IEC Lead (5m)		PASS		13 Amp	240V		PASS	PASS	PASS	
Light 2	Bowens Esprit GM500 Flash Head	ULO222	PASS	Class 1	5 Amp	240V		PASS	PASS	PASS	
Lead 2	IEC Lead (5m)		PASS		13 Amp	240V		PASS	PASS	PASS	
Charger 1	Wireless Flash Trigger Charger		PASS		0.25A	240V				PASS	
Charger 2	Wireless Flash Trigger Charger		PASS		0.25A	240V				PASS	
Extn 2	1 Way Extension (10m)		PASS		13 Amp	240V		PASS	PASS	PASS	
Extn 3	6 Way Extension Bar (1m)		PASS		13 Amp	240V		PASS	PASS	PASS	1 socket unusable due to Earth Lock
Godox 1	RS600P Portable Flash Battery Pack Charger		PASS	Class 2	2.8 Amp	14.6V				PASS	
Lead 7	IEC Lead (0.5m)		PASS		13 Amp	240V		PASS	PASS	PASS	
Godox 2	RS600P Portable Flash Battery Pack Charger		PASS	Class 2	2.8 Amp	14.6V				PASS	
Lead 8	IEC Lead (0.5m)		PASS		13 Amp	240V		PASS	PASS	PASS	

Location: Sheffield City Hall
 Barkers Pool
 Sheffield S1 2JA

Martyn Mackie Photography
 No 2 Avenue 1 Westgate Park
 Westgate, Morecambe, LANCS, LA3 3DE
 Tel: 01524 832175 Mobile: 07788 961788